

Reference Conductance Values to be used with Midtronics SCP6/12 tester

Model	Fully Charged Reading (Siemens)
PS-610	45
PS-612	35
PS-630	95
PS-640	115
PS-670	170
PS-6100	250
PS-1212	40
PS-1221	60
PS-1230	95
PS-1242	80
PS-1270	200
PS-12120	330
PS-12170	400
PS-12260	320
PS121000	1150

Note: Values given should only be used as a guideline.

Information on creating ref values and faq on Midtronics and conductance testing can be seen on the below link

<http://www.stationary-power.com/support--reference-values/frequently-asked-questions/>